

Inverter SN:

Modle Name:

Firmware Version:

Safety Code:

Remote:

Local:

Test Item:	59.S1	59.S2	27.S1	27.S2
Trip Limit Set:	253V	264.5V	195.5V	34.5V
Trip Time Set:	603s	0.2s	1.5s	0.2s
Test Result:	Pass	Pass	Pass	Pass
Vac:	233.7V	232.4V	233.2V	232.5V
Vac Off:	233.7V	232.6V	234.1V	233.2V
T Off:	603s	0.20s	1.48s	0.18s

Test Item:	81>.S1	81<.S1	81>.S2	81<.S2
Trip Limit Set:	50.2Hz	49.8Hz		
Trip Time Set:	0.1s	0.1s		
Test Result:	Pass	Pass		
Fac:	50.00Hz	50.01Hz		
Fac Off:	50.00Hz	50.02Hz		
T Off:	0.10s	0.10s		

REMOTE: 1
LOCAL: 1

Inverter SN:

Modle Name:

Firmware Version:

Safety Code:

Remote:

Local:

Test Item:	59.S1	59.S2	27.S1	27.S2
Trip Limit Set:	253V	264.5V	195.5V	34.5V
Trip Time Set:	603s	0.2s	1.5s	0.2s
Test Result:	Pass	Pass	Pass	Pass
Vac:	237.0V	237.3V	233.2V	236.4V
Vac Off:	237.0V	238.3V	234.1V	237.0V
T Off:	603s	0.20s	1.48s	0.18s

Test Item:	81>.S1	81<.S1	81>.S2	81<.S2
Trip Limit Set:			51.5Hz	47.5Hz
Trip Time Set:			0.1s	0.1s
Test Result:			Pass	Pass
Fac:			50.01Hz	50.01Hz
Fac Off:			50.00Hz	50.01Hz
T Off:			0.10s	0.10s

REMOTE: 1
LOCAL: 0

ESEMPIO AUTOTEST VISSMANN HYBRID 5.0-1