

Inverter SN:

Modle Name:

HINV3.0-1

Firmware Version:

0909A

Safety Code:

Italy

Remote:

1

Local:

1

Test Item:	59.S1	59.S2	27.S1	27.S2
Trip Limit Set:	253V	264.5V	195.5V	34.5V
Trip Time Set:	603s	0.2s	1.5s	0.2s
Test Result:	Pass	Pass	Pass	Pass
Vac:	231.2V	231.7V	230.2V	232.2V
Vac Off:	231.2V	231.2V	231.4V	232.6V
T Off:	603s	0.20s	1.49s	0.19s

Test Item:	81>.S1	81<.S1	81>.S2	81<.S2
Trip Limit Set:	50.2Hz	49.8Hz		
Trip Time Set:	0.1s	0.1s		
Test Result:	Pass	Pass		
Fac:	49.99Hz	49.97Hz		
Fac Off:	49.99Hz	49.99Hz		
T Off:	0.10s	0.10s		

REMOTE: 1

LOCAL: 1

Inverter SN:

Modle Name:

HINV3.0-1

Firmware Version:

0909A

Safety Code:

Italy

Remote:

1

Local:

0

Test Item:	59.S1	59.S2	27.S1	27.S2
Trip Limit Set:	253V	264.5V	195.5V	34.5V
Trip Time Set:	603s	0.2s	1.5s	0.2s
Test Result:	Pass	Pass	Pass	Pass
Vac:	232.8V	234.2V	236.0V	236.9V
Vac Off:	232.8V	234.6V	236.4V	236.0V
T Off:	602s	0.20s	1.48s	0.19s

Test Item:	81>.S1	81<.S1	81>.S2	81<.S2
Trip Limit Set:			51.5Hz	47.5Hz
Trip Time Set:			0.1s	0.1s
Test Result:			Pass	Pass
Fac:			49.98Hz	50.01Hz
Fac Off:			49.98Hz	50.02Hz
T Off:			0.10s	0.10s

REMOTE: 1

LOCAL: 0

ESEMPIO AUTOTEST VIESSMANN HYBRID 3.0-1