

Technical Compliance Statement

EMC Test Report



中国认可
国际互认
检测
TESTING
CNA S L8489

For the following information

Ref. File No.: C1W2308052

Applicant : Viessmann Climate Solutions SE

Manufacturer : Viessmann Climate Solutions SE

Product : Viessmann Hybrid Inverter

Model Number : (1)Viessmann Hybrid Inverter 15.0G-3
(2)Viessmann Hybrid Inverter 20.0G-3
(3)Viessmann Hybrid Inverter 25.0G-3
(4)Viessmann Hybrid Inverter 29.9G-3
(5)Viessmann Hybrid Inverter 30.0G-3

Brand : **VIESSMANN**

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards. The test data & results are issued on the EMC test report No. **ACWE-E2312026**.

Emission: EN IEC 61000-6-3:2021, EN 61000-6-3:2007+A1:2011+AC:2012
EN IEC 61000-6-4:2019, EN 61000-6-4:2007+A1:2011*
(IEC 61000-6-3:2020, IEC 61000-6-4:2018) and
AS/NZS 61000.6.3:2021•*, AS/NZS 61000.6.4:2012•*, AS 61000.6.4:2020•*
EN 55011:2016+A11:2020•, EN 55011:2016+A2:2021•
EN 61000-2-2:2002+A2:2019•*,
CISPR11:2015+AMD1:2016+AMD2:2019CSV
EN 61000-3-12:2011, EN IEC 61000-3-11:2019, EN 61000-3-11:2011
(IEC 61000-3-12:2011, IEC 61000-3-11:2017)

Immunity: EN IEC 61000-6-1:2019, EN 61000-6-1:2007
EN IEC 61000-6-2:2019, EN 61000-6-2:2005+AC:2005•*
(IEC 61000-6-1:2016, IEC 61000-6-2:2016)
(IEC 61000-4-2:2008, IEC 61000-4-3:2020, IEC 61000-4-4:2012,
IEC 61000-4-5:2014+A1:2017•, IEC 61000-4-6:2013+COR1:2015,
IEC 61000-4-8:2009, IEC 61000-4-34:2005+A1:2009•*)

•means part of the standard is not included in Audix's CNAS scope, but the test capability can meet regulatory requirement.

*means part of the standard is not included in Audix's DAkkS scope, but the test capability can meet regulatory requirement.

Dec.27, 2023

K.M Tong/Assistant Manager
AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.



The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.