

Technical Compliance Statement Test Report



中国认可
国际互认
检测
TESTING
CNA S L8469

For the following information

Ref. File No.: C1W2506041

Applicant : Viessmann Climate Solutions GmbH & Co. KG
Manufacturer : Viessmann Climate Solutions GmbH & Co. KG
Product : Hybrid Inverter
Model Number : (1) Viessmann Hybrid Inverter 40G-3
(2) Viessmann Hybrid Inverter 50G-3
Brand : **VIESSMANN**

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards. The test data & results are issued on the EMC test report No. **ACWE-E2506029**.

Emission: EN 62920:2017+A1:2021•; IEC 62920:2017+A1:2021•
EN IEC 61000-6-3:2021, EN 61000-6-3:2007+A1:2011+AC:2012
EN IEC 61000-6-4:2019, EN 61000-6-4:2007+A1:2011*
(IEC 61000-6-3:2020, IEC 61000-6-4:2018) and
AS/NZS 61000.6.3:2021•; AS/NZS 61000.6.4:2012•*; AS 61000.6.4:2020•
EN 55011:2016+A1:2020•; EN 55011:2016+A2:2021•
EN 61000-2-2:2002+A2:2019•*, IEC 61000-2-2:2018•*
EN IEC 61000-3-11:2019, EN 61000-3-11:2000,
EN 61000-3-12:2011+AC:2013, EN 61000-3-12:2011
(IEC 61000-3-11:2017, IEC 61000-3-12:2011+AMD1:2021)

Immunity: EN 62920:2017+A1:2021•; IEC 62920:2017+A1:2021•
EN IEC 61000-6-1:2019, EN 61000-6-1:2007 (IEC 61000-6-1:2016)
EN IEC 61000-6-2:2019, EN 61000-6-2:2005 (IEC 61000-6-2:2016)
(IEC 61000-4-2:2008, IEC 61000-4-3:2020, IEC 61000-4-4:2012,
IEC 61000-4-5:2014+A1:2017•, IEC 61000-4-6:2023, IEC 61000-4-8:2009
IEC 61000-4-34:2005+A1:2009•*)

•means part of the standard is not included in Audix's CNAS scope, but the test capability can meet regulatory requirement.

*means part of the standard is not included in Audix's DAkkS scope, but the test capability can meet regulatory requirement.

Jul.02, 2025

K.M Tong/Assistant Manager

AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.



The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.