

KEMA TYPE TEST CERTIFICATE OF TEMPERATURE-RISE PERFORMANCE

Qingdao TGOOD Electric Co., Ltd.,

Qingdao, China

has successfully passed the type test sequence on a three-pole

GIS

Type: TGP 145-40-31 and TDS 145-40-31

Rating: 145 kV – 3150 A – 50/60 Hz

The test object passed the specification of test duties of

IEC 62271-203


subclauses 6.4 and 6.5 (temperature-rise test)

The test results are recorded in Certificate No.

1484-15

This Certificate was issued on 18 March 2016

KEMA Nederland B.V.


J.P. Pontejne
Executive Vice President
KEMA Laboratories



KEMA

Laboratories

© DNV GL

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that DNV GL has certified or approved any object other than the specimen tested.