

KEMA TYPE TEST CERTIFICATE OF SWITCHING PERFORMANCE

Qingdao TGOOD Electric Co., Ltd.

Qingdao, China

has successfully passed the type test sequence on a three-pole dead-tank

SF₆ circuit-breaker

Type: TCB 145-40-31

Rating: 145 kV – 3150 A – 40 kA – 50/60 Hz

The test object passed the specification of test duties of

IEC 62271-100

subclauses 6.102 and 6.111 (Capacitive current switching).

The test results are recorded in Certificate No.

2154-16

This Certificate is issued on 12 August 2016

KEMA Nederland B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA Laboratories

