

## KEMA TYPE TEST CERTIFICATE OF SHORT-CIRCUIT PERFORMANCE

### **Qingdao TGOOD Electric Co., Ltd.**

Qingdao, China

has successfully passed the type test sequence on a  
compact

### **switchgear assembly**

Type: THP 145-40-25

Rating: 145 kV – 2500 A – 40 kA – 50/60 Hz

The test object passed the specification of test duties of

### **IEC 62271-205**

subclauses 6.6 (STC)

The test results are recorded in Certificate No.

**2155-16**

This Certificate is issued on 12 August 2016

KEMA Nederland B.V.



J.P. Fonteijne  
Executive Vice President  
KEMA Laboratories

**KEMA** Laboratories

